



0000117754

ORIGINAL

Diversified Water Utilities, L.L.C.
P.O. Box 17357
Phoenix, Arizona 85011
(602) 840-9400

RECEIVED

2002 OCT -2 P 12:44

October 1, 2002

AZ CORP COMMISSION
DOCUMENT CONTROL

Docket Control
Utilities Division
Arizona Corporation Commission
1200 West Washington
Phoenix, Arizona 85007

Re: Compliance Filing for Docket Nos. ~~WS-02234A-00-0571~~; WS-02987A-99-0583; WS-02987A-00-0618 and W-02859A-00-0774
Under Decision No. 63960 as Amended by Decision No. 64062
ADEQ Compliance Status Report

Gentlemen,

In compliance with the requirements of Decision No. 63960 as Amended by Decision No. 64062, Diversified Water Utilities, Inc. ("DWU") files its Compliance Status Report dated September 24, 2002, issued by the Arizona Department of Environmental Quality ("ADEQ") showing that DWU is in compliance with the rules and regulations of ADEQ. This filing is in pursuant to the requirements of paragraph 167 of the above referenced Decisions issued by the Arizona Corporation Commission.

For the purpose of correcting the public record, the nitrate reading set forth in the Compliance Status Report is incorrect. Upon discovery of the error, the resample taken by DWU for nitrate showed a reading of 0.31 for nitrate.

The ADEQ Compliance Status Report shows that DWU complies with the requirements established for the first year by the Decisions. If additional information is required, please contact me.

Sincerely,

Scott W. Gray
President

Arizona Corporation Commission
DOCKETED

OCT 02 2002

DOCKETED BY	CA
-------------	----

Arizona Department of Environmental Quality
Drinking Water Compliance Enforcement Unit
3033 N. Central Avenue, M0501B
Phoenix, AZ 85012

Compliance Status Report

PWS Name: Diversified Water

PWS ID #: 11-043

Compliance Status: ☒ No Major Deficiencies ☐ Major Deficiencies
Comments:

This water systems 3/02 nitrate result was 9.75 mg/L, which is over the trigger of 5.0 mg/L. Water systems that have a nitrate result over the trigger are required to perform quarterly nitrate monitoring for 4 consecutive quarters. ADEQ has evidence that Diversified Utilities has completed 1 quarter of the required 4 quarters of increased nitrate monitoring.

5 lead and copper samples are due during June through September, 2002. The system may request a reduction in sampling to once every 3 years after 2002 samples are completed.

Date of last inspection / sanitary survey: 11/2/00

Major unresolved/ongoing Operation and Maintenance (O&M) Deficiencies:

☒ None ☐ unable to maintain 20psi ☐ inadequate storage
☐ cross connection/backflow problems ☐ surface water treatment rule
☐ treatment deficiencies ☐ approval of construction
☐ certified operator

Administrative Orders:

Is ADEQ administrative order in effect? ☐ Yes ☒ No
Is US EPA administrative order in effect? ☐ Yes ☒ No

Comments:

System information:

Number of Points of Entry 1 Population Served 210 Connections Served 60
Initial Monitoring Year 1995 MAP year 2004

DWCE Evaluation completed by: Sally Ceccarelli-Wolf Compliance Officer

Phone: (602) 771-7626 Date: September 24, 2002

Based on data submitted by the water system, ADEQ has determined that this system is currently delivering water that meets water quality standards required by Arizona Administrative Code, Title 18, Chapter 4. This compliance status report does not guarantee the water quality for this system in the future. This compliance status report does not reflect the status of any other water system owned by this utility company.